



CBUL.R13770

## Encapsulant Materials

[See General Information for Encapsulant Materials](#)

### **FIBERLOCK TECHNOLOGIES INC**

R13770

150 DASCOMB RD

ANDOVER, MA 01810 USA

Fiberset FT or Fiberset FT White post removal encapsulant materials for use with Classified Types RG , RG1 and 106 cementitious mixtures manufactured by Zonolite Construction Products Div., W. R. Grace & Co., applied at an application rate of not less than 1000 sq ft/gal to beams, columns, joists, roof-ceiling assemblies consisting of all fluted galvanized steel roof deck and floor-ceiling assemblies consisting of all fluted or cellular steel floor and form units or cellular/fluted blends provided that the underside of the units receives a coat of Type SK-3 prior to the application of the cementitious mixture. The ability of these materials to act as a sealant has not been investigated.

Fiberset PM Clear 7475 or Fiberset PM White 7470 post removal encapsulant materials for use with Classified Types RG , RG1 and 106 cementitious mixtures manufactured by Zonolite Construction Products Div., W. R. Grace & Co., applied at an application rate of not less than 500 sq ft/gal to beams, columns, joists, roof-ceiling assemblies consisting of all fluted galvanized steel roof deck and floor-ceiling assemblies consisting of all fluted or cellular steel floor and form units or cellular/fluted blends provided that the underside of the units receives a coat of Type SK-3 prior to the application of the cementitious mixture. The ability of these materials to act as a sealant has not been investigated.

Firebond concentrate post removal encapsulant material for use with Classified Types RG , RG1, MK-6/CBF, MK-6/ED, MK-6/HY, MK-6s and 106 cementitious mixtures manufactured by Zonolite Construction Products Div., W. R. Grace & Co., applied at an application rate of not less than 1000 sq ft/gal on beams, columns, joists roof-ceiling assemblies consisting of all fluted galvanized steel roof deck and floor-ceiling assemblies consisting of all fluted steel floor and form units or cellular/fluted blends consisting of one or more fluted units to one maximum 24 in. wide cellular unit provided that the underside of the units receives a coat of Type SK-3 prior to the application of the cementitious mixture. The ability of this material to act as a sealant has not been investigated.

Firebond adhesive post removal encapsulant material for use with Classified Types RG , RG1, MK-6/CBF, MK-6/ED, MK-6/HY, MK-6s and 106 cementitious mixtures manufactured by Zonolite Construction Products Div., W. R. Grace & Co., applied at an application rate of not less than 500 sq ft/gal on beams, columns, joists, roof-ceiling assemblies consisting of all fluted galvanized steel roof deck and floor-ceiling assemblies consisting of all fluted steel floor and form units or cellular/fluted blends consisting of one or more fluted units to one maximum 24 in. wide cellular unit provided that the underside of the units receives a coat of Type SK-3 prior to the application of the cementitious mixture. The ability of this material to act as a sealant has not been investigated.

**Last Updated** on 2002-07-22

---

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

